

## Mandatory Language for Public Notice

### Triggered Source Monitoring and Reporting Violation: Groundwater Rule

Village of Surfside Beach - PWS ID # 0200037 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the groundwater system during May / 2021. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active groundwater well source. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

#### What should I do?

There is nothing you need to do at this time.

#### What is being done?

Water Department staff was educated as to the specific state rules for Triggered Source sampling requirements. Additionally, the department preformed a Level 2 Assessment for sanitary defect on June 03, 2021. The filed investigation and information were compiled into level 2 assessment report and forwarded to the required state agency.

For more information, please contact Gregg Bisso, Mayor at 979-233-1531 Ext 104 or 1304 Monument Dr, Surfside Beach, Texas 77541.

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

---